



ALASKA RAILROAD CORPORATION  
327 W. Ship Creek Ave.  
Anchorage, AK 99501  
Phone 907-502-0007  
[HumphreyC@akrr.com](mailto:HumphreyC@akrr.com)

February 3, 2021

**Addendum Number 1**  
**Request for Quote 21-RFQ-208781**  
**Bearing Assembly Structural Steel, Shim Packs & Structural Fasteners**

This addendum is being issued to provide information as follows:

---

**BIDDER QUESTIONS:**

General

1. Do the bearing plates need to conform to the T3 requirement per the structural steel callout in the notes? Generally that level of testing is for fracture critical members not bearing plates.

*Answer: No*

2. Are you wanting pricing on the upper bearing plates (EBP & FBP)?

*Answer: Yes.*

*This RFQ does not include the Elastomeric Bearing Pads & Bearing Pads. Elastomeric Bearing Pads will not be vulcanized to the Bearing Plate as shown.*

3. Are you wanting pricing on the anchor bolts?

*Answer: Anchor bolts are part of 21-RFQ-208781 - Bearing Assembly Structural Steel, Shim Packs & Structural Fasteners. See Cost Schedule.*

---

Please acknowledge receipt of this and all addendums via email. **All other dates, terms and conditions remain unchanged.**

Please direct all responses and/or questions concerning this solicitation to Candice Humphrey, via email; [HumphreyC@akrr.com](mailto:HumphreyC@akrr.com) .

Respectfully,

Candice Humphrey  
Contract Administration Specialist