



ALASKA RAILROAD CORPORATION
327 W. Ship Creek Ave.
Anchorage, AK 99501
Phone 907-265-4467
Fax 907-265-2439
HopeM@akrr.com

September 7, 2022

Addendum Number 7

ITB 22-02-209508

Trail River Bridge 25.7 and Falls Creek Bridge 25.4 Replacements

This Addendum is being issued to provide information as follows:

1. Bid Due date is changed to 3:00 pm, September 13, 2022.

Question & Answers:

2. **Q:** Sheet C9 of Attachment 1.1 appears to show the Crown Point Mine Road as being 8" base course. C4 does as well. The ITB Page 200 refers to 4" asphalt, asphalt binder, etc. It doesn't show a typical width, striping, etc. Please clarify if asphalt is required on this road and provide details if so.

A: Asphalt is required. Lane widths are 8-feet. No striping is required in this crossing. Please refer to the ITB description of item 617.0001.1 – Railroad Crossing and lump sum breakdown table within. Also see Attachment 2.1 - ARRC 2-78.06 25.7 for further detail of the work.

3. **Q:** C9 also says to raise existing panels there, but ITB says we install new panels. And the C9 shows installing culvert inlet and outlet protection and the ITB doesn't mention it.

A: Install new RR furnished panels per the ITB and Attachment 2.1 - ARRC 2-78.06 25.7. Install culvert inlet protection per approved SWPPP.

4. **Q:** When would the ARRC-supplied materials be available to the contractor (i.e. – precast concrete members, steel sheet and Tee piling, trackwork, ballast, and ties)?

A: All ARRC supplied materials can be made available by 1 November 2022.

5. **Q:** Will Railroad Protective insurance be required on this project?

A: Yes, please add the following

“If any part of the work to be performed on ARRC Property is located within fifty feet (50’) of a railroad track, then the Permittee/Contractor shall also obtain Railroad Protective Liability insurance (Alaska Railroad Corporation as named insured) with limits of liability of not less than \$5,000,000 Combined Single Limit for Bodily Injury and Property Damage per each accident or loss.”

All other terms and conditions remain unchanged.

Acknowledge receipt of this and all addenda in your firm’s Construction Bid Form (Form 395-0121).

Sincerely,



Michele Hope
Sr. Contract Administrator