



ALASKA RAILROAD CORPORATION

327 W. Ship Creek Ave.

Anchorage, AK 99501

ThompsonC@akrr.com

Phone 907-265-2068

Cell 907-854-3141

April 28, 2025

Addendum Number 3

Invitation to Bid 25-22-213097

ARRC Seattle PIER 15.5 COATING

ITB closing date, Offers will be received UNTIL 3:00 PM LOCAL TIME ON MAY 1, 2025

This addendum is being issued to provide information as follows:

Question 1: In Appendix G Technical specs, Part 2 Products, Section 3.3 Zone 2.B Surface preparation, requires a minimum 3.0 mil profile, and, Section 3.3 Zone 2.C: Comply with manufactures written installation procedures and individual product data sheet application bulletins. Per Belzona 5831 Manufacture's surface preparation installation, can be meet with UHP Hydroblasting (2000-2500 bar) to remove previous coatings and expose original profile. Will ARRC accept this Manufactures surface preparation, in lieu of the required minimum 3.0 mil profile?

Answer 1: ARRC will accept manufacture's surface preparation of UHP Hydroblasting (2000-2500 bar) to remove previous coatings and expose original profile, with the following submittals: Manufacture's Letter of Surface preparation, and Manufactures warranty associated with UHP Hydroblasting surface preparation.

Sincerely,

C. Lee Thompson

Contract Administrator

Alaska Railroad Corporation