



ALASKA RAILROAD CORPORATION

327 W. Ship Creek Ave.

Anchorage, AK 99501

wallaces@akrr.com

Phone (907)265-2425

Cell (907)744-0031

ADDENDUM NO. 1

Invitation to Bid (ITB) 26-24-214676

Pease Ave & Artillery Rd Paving

Alaska Railroad Corporation

Date: July 14, 2026

This Addendum No. 1 is issued to provide clarification in response to questions. All other terms and conditions of the referenced solicitation remain unchanged.

QUESTION AND ANSWERS:

1. 4" of D1 on both crossings?
[Up to a maximum of 4"](#)
2. 4" of Asphalt in 2" lifts on each crossing?
[Correct](#)
3. Will there be 2 mobes demobes if there are 2 crossings? Or will the AKRR have both ready to pave at the same time? These crossings are miles apart from each other.
[Yes. Correct bid Item 640.0001 to have a quantity of 2](#)
4. Since these crossings are on base who will approve the TCP's?
[TCP will be approved by JBER](#)
5. 643.0002 Traffic Maintenance. Assuming the reference is Section 643 Traffic Maintenance? If so, this Section has references to a lot of requirements that wouldn't necessarily pertain to this project. Are there any supplemental conditions that refer to the specific requirements for this project?
[Traffic Maintenance Basis of Payment is covered in section 643-5.01. The Scope of work states that the roads will be fully closed during work.](#)
6. Is ARRC doing the track work in one shift or two shifts? This information will impact the Traffic Control Plan. Is ARRC doing the two projects simultaneously? And How many days will these crossings be closed for?
[ARRC will only be operating one shift. The projects will not be running simultaneously. ARRC expects each crossing to be closed for a maximum of four \(4\) days.](#)
7. "Traffic Price Adjustment ALL REQUIRED". Please clarify. 643.0023 Traffic Price Adjustment. What calculation are you wanting us to use for the Bid Schedule? This appears to be an assessment/ liquidated damages made by ARRC not by the Contractor.
[This is liquidated damages made by ARRC.](#)

8. Will the traffic paint be surface applied, or inland?
Bid Item 670.0001. ___ is for Surface applies markings
9. Will the paint need to be MMA?
No
10. At peace there are currently no painted stop bars, will you require them on both crossings?
Pease currently has stop bars and RXR markings and they will be required to be replaced in accordance with the MUTCD. Artillery is currently unpaved and will require stop bars.
11. At peace, if we cut and remove approximately 48 feet on either side of the tracks we will not have to cut into the top of the RXR markings, will this be acceptable?
Yes
12. "Removal of pavement marking symbols Peace Ave "are there additional pavement marking symbols that need to be removed? Other than the ones that will be removed when we rip up the asphalt?
No
13. Page 15, 1. Permits states that the permits are attached but I did not find the attached permit. Will this be provided?
Section 107.102 states "The contractor shall: Acquire any permits and licenses required to complete the project that are not acquired by the owner." ARRC has acquired no permits for this project.
14. None of the xxx-0000 numbers listed in your Cost Schedule are in the Orange Book.
All the referenced cost schedule item numbers are contained within the Alaska Railroad Corporation (ARRC) 2025 *Standard Specifications for Construction* ("Orange Book") and correspond to the specification sections and page references identified below.

Cost Schedule Items/SSC Reference Pages:

Item No. **202.0002** – Section 202, *Removal of Structures and Obstructions*, pages 104–108.

Item Nos. **301.0001.1** and **301.0001.2** – Section 301, *Aggregate Base and Surface Course*, pages 124–125.

Item Nos. **401.0001.1** and **401.0002.2** – Section 401, *Hot Mix Asphalt Pavement*, pages 141–157 (Basis of Payment on pages 156–157).

Item No. **640.0001** – Section 640, pages 398–399.

Item No. **643.0002** – Section 643, pages 450–452.

Item Nos. **670.0001.1**, **670.0001.2**, and **670.0016** – Section 670, pages 500–504.

Reference: Alaska Railroad Corporation, *2025 Standard Specifications for Construction (Orange Book)*. Available at:
<https://www.alaskarailroad.com/sites/default/files/procurement/2025%20ARRC%20SSC.pdf>

15. Will Artillery gate be accessible for access when we do Artillery crossing?

Artillery gate will be accessible for access during the work on Artillery crossing

16. Will post gate be accessible for access when we do peace crossing?

The Alaska Railroad Corporation is currently waiting for a response from JBER, but the expectation is that post gate will not be available.

Please acknowledge receipt of this and all addenda in your firms Supply Bid Form (Form 395-0129).

Sincerely,

A handwritten signature in cursive script that reads "Sarah B. Wallace".

Contract Administration Specialist
Alaska Railroad Corporation