

August 1, 2022

Addendum Number 4

ITB 22-41-209504 Bridge 147.4 Pier Replacements

This Addendum is being issued to provide information as follows:

Question & Answers:

1. Q: Will spiral weld pipe be acceptable for the piling? It has been in the past and will shorten procurement time.

A: Spiral weld pipe is not acceptable at this time.

 Q: Is it allowable to "No Bid" one or more alternate pile items if they can't be made in time or if a minimum order is vastly over the quantity required by this project?
A: "No bids" for additive alternatives are allowable.

All other terms and conditions remain unchanged.

Acknowledge receipt of this and all addenda in your firm's Construction Bid Form (Form 395-0121).

Sincerely,

Michele Hope

Michele Hope Contract Administrator